

GENERAL INFORMATION - WOODSTOVE & CHIMNEY INSTALLATIONS

Inspections:

1. It is recommended that we be called prior to you installing your woodstove and chimney to ensure proper clearances will be met for the stove, flue pipe, walls and floor.
2. The manufacturers installation manual for stove and chimney is to be available on site at the time of inspection.
3. Carbon Monoxide Detectors shall be installed on or near the ceiling adjacent to each sleeping area; and shall
 - a) Be wired so that its activation will activate all Carbon Monoxide Detectors within the suite.
 - b) Be equipped with an alarm that is audible within bedrooms when the intervening doors are closed.

In existing structures, the Carbon Monoxide Detector may be battery operated or plugged into an electrical outlet.

Approved detectors to conform with CAN/CGA-6.19 Residential Carbon Monoxide Detectors CSA 6.19 "Residential Carbon Monoxide Alarming Devices", or UL2034 Single and Multiple Station Carbon Monoxide Detectors.

SAFETY CONSIDERATIONS:

- § Fire extinguisher – min. type of 1A/5BC rated
- § Thermostat on flue pipe
- § Carbon monoxide detector on replacements
- § House numbers posted and visible from street
- § Fire Department phone number and your address by the phone

RECOMMENDATIONS:

- § Removal of ashes into a metal pail
- § Storage of wood – kept dry
- § Condition of wood – non-green
- § Chimney inspected and cleaned yearly